

# 1050 Termination Bar

SECTION 04 00 00 MASONRY  
Section 04 05 23 Masonry Accessories  
Section 07 62 00 Sheet Metal Flashing and Trim

**PART 1: GENERAL**

1.1 RELATED SECTIONS

A. Provide shop drawings for all product locations.

1.2 SUBMITTALS

A. Manufacturer Certificate of Compliance for materials.

B. Product Data: Manufacturer's data sheet on each type of product furnished.

**PART 2: MANUFACTURER**

2.1 MANUFACTURER

Acceptable Manufacturer:  
Heckmann Building Products  
110 Richards Ave.  
Norwalk, CT 06854-1685  
800-621-4140  
Email: [info@heckmannanchors.com](mailto:info@heckmannanchors.com)  
Website: [www.heckmannanchors.com](http://www.heckmannanchors.com)

2.2 APPLICATIONS

- A. Provide anchoring systems that comply with TMS 402/602-22 Building Code Requirements and Specification for Masonry Structures 2022.
- B. Stainless Steel AISI [Type 304] or [Type 316].
- 1) ASTM A240/A240M-24b Standard Specification for Chromium and Chromium Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications.
  - 2) ASTM A666/666M-24 Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar.
  - 3) ASTM A276/A276M-24a Standard Specification for Stainless Steel Bars and Shapes.

2.3 MATERIALS

## **NO. 1050 TERMINATION BAR**

### **A. Standards**

1050-T1-SS: 1/8" x 1" wide x 8ft Stainless - no lip

1050-T2-P 1/8" x 1" wide x 8ft - plastic - with lip

1050-T1-A 14 gauge x 1" x 8ft Aluminum - no lip

1050-T2-A 14 gauge x 1" x 8ft Aluminum - with lip

1050-T2-SS 26 gauge x 1-1/2" wide x 8ft - with lip

### **B. Specials**

Thickness: [1/8"] [14 gauge] [16 gauge] x [width] x [length] x [hole diameter] x  
[hole spacing oc] x hole to start [inches] from end.

### **C. Materials: [Type 304 Stainless Steel]**

## **PART 3: EXECUTION**

A. Install as specified in applicable Masonry/Sheet Metal Flashing section(s).